1423 Main St. A/C System Install date / time





Jim T. Technician

Date of Service: Time of Service:

6/12/2022 10:00 AM

Sample Report





Test In A/C Vitals

In Range 💙

Mick Richardson 264 Harding Court Loveland, CO 80538

Date of Service: 8/9/2022 Time of Service: 10:49:14 PM

What Are Your System Vitals?

Just like your health vitals, temperature, pulse, blood pressure etc, your A/C system vitals show the overall health of your air conditioning system. These vitals account for both the refrigerant and air delivery side of the system. System targets that are out of range are typically related to a system diagnostic listed below. Correcting the diagnostic faults, if possible, should put the system vitals back in the normal range.



Out of Range

Refrigerant Charge



Heat Transfer

Condenser App	proach: °F		Temperature S	plit: 16.6 °F	
Low	Normal (1.5 - 20.0)	High	Low	Normal (12.3 - 19.7)	High
				{~}	

Air Distribution & Filtration

Total External Static Pressure: 0.41 inH2O		Filter Face Velocity: 134.8 FPM				
Low	Normal (< 0.7)	High	Low	Normal (< 500.0)	High	
Subsystem Review	,		System Diagnostic	CS		
Not yet reviewed		Liquid line is below	outdoor air temperature	14		
		System may be over	ercharged w/ refrigerant	4		
			Dirty condenser or	non-condensibles	3	



©2021 Manifold Cloud Services Ltd. | measureQuick.com





Age & Efficiency Losses -6 The system age scoring is based upon the initial system SEER, capacity, installation date and climate zone. Larger higher capacity systems in hot climates have been shown to age at a faster rate. **Temperature Split Losses** Split losses are directly tied to sensible capacity. Systems with a low temperature split may have a refrigerant charge issue, or more common, a return duct leak that could result in excessive run times and substantial energy losses. **Static Pressure Losses** High system static pressure can result in high fan watt draw (electrical usage) and/or low airflow as well as premature blower motor failure, especially with ECM/Constant Torque motors. The system can have high total static, supply static, return static or a combination of all three. High static can also exacerbate return air duct leakage and contribute to poor indoor air quality. Approach Losses A system with high approach has heat rejection issues. This can be the result of a dirty condenser, non condensibles, condenser clearances, and/or condenser air recirculation. Systems with a high approach may also have a low temperature split due to heat returning to the metering device through the liquid line. Refrigerant Charge Losses Refrigerant charge losses can be the result of a refrigerant undercharge, overcharge and/or non-condensibles. measureQuick considers the deviation in charge from superheat/subcooling targets as well as the metering device type. Fixed/ piston metering devices will result in high capacity losses when the system is undercharged. **Your System Score**

Using data from several studies that correlate system faults, and system degradation due to age, measureQuick uses a proprietary scoring system to grade the system based upon age and system fault intensity. New systems when properly installed should easily score 95-100%.

86% B



©2021 Manifold Cloud Services Ltd. | measureQuick.com



Jane Smith 1423 Main St Your City, OH 54321

Date of Service: 6/12/2022 Time of Service: 10:36:22 AM

What Are Your System Vitals?

Just like your health vitals, temperature, pulse, blood pressure etc, your A/C system vitals show the overall health of your air conditioning system. These vitals account for both the refrigerant and air delivery side of the system. System targets that are out of range are typically related to a system diagnostic listed below. Correcting the diagnostic faults, if possible, should put the system vitals back in the normal range.

YOUR SYSTEM SCORE

Test In Measurement Details

85% B

Outdoor Measurements

Low Pressure (PSIG)	118.0	Job Link
High Pressure (PSIG)	390.0	Job Link
Suction Line Temp (F)	50.0	Job Link
Liquid Line Temp (F)	91.0	Job Link
Discharge Line Temp (F)	170.0	
Outdoor Air Temp (F)	85.0	JobLink
Superheat (F)	10.3	⊞
Subcooling (F)	23.8	⊞
Compression Ratio	3.0	▦
Cond. Volts	231.2	f
Cond. Amps	8.5	f
Cond. Power Factor	0.95	f
Cond. Power (W)	1792	A

Indoor Measurements

Job Link

翩

Job Link

Job Link

翩

囲

Job Link

Return Temp (F) 75.0 Return %RH (%) 50.0 Return Wet Bulb (F) 62.6 Supply Temp (F) 58.0 Supply %RH (%) 81.0 Supply Wet Bulb (F) 54.6 Est. Airflow (SCFM) 1371 TESP (inH2O) 0.50 AHU Volts 110.0 AHU Amps 4.0 AHU Power Factor 0.95 AHU Power (W) 897

System Info & Weather

System Type	Split	
Nominal Tonnage (Tons)	3	
Refrigerant	R410A	
Rated Airflow	400	
SEER	13-16	
Metering Device	TXV	
Atmos. Pressure (psia)	14.696	
Elevation (ft)	5012	
Benchmarked	No	
System Stability	Stable	

Performance Calculations

Nominal Capacity (Tons/Btuh)	3.0 / 36,00
Normalized Capacity (Tons/Btuh)	2.7 / 32,67
Actual Capacity (Tons/Btuh)	2.6 / 31,434 (96% Normalize
Sensible Capacity (Tons/Btuh)	2.1 / 25,271 (114% Normalize
Latent Capacity (Tons/Btuh)	0.5 / 6,163 (58% Normalize
Sensible Heat Ratio	0
Temp Split Target (F)	17
Temp Split (F)	17
Dehumidification (lb/hr)	
Fan Efficacy (W/SCFM)	
Total Power (W)	268
EER	11
Approx. SEER	13



measureQuick

©2022 Manifold Cloud Services Ltd. | measureQuick.com



Test Out A/C Vitals

In Range 💟

Jane Smith 264 Harding Court Loveland, CO 80538

Date of Service: Time of Service: 11:09:08 PM

6/12/2022

What Are Your System Vitals?

Just like your health vitals, temperature, pulse, blood pressure etc, your A/C system vitals show the overall health of your air conditioning system. These vitals account for both the refrigerant and air delivery side of the system. System targets that are out of range are typically related to a system diagnostic listed below. Correcting the diagnostic faults, if possible, should put the system vitals back in the normal range.



Out of Range

Refrigerant Charge



Heat Transfer

Condenser App	oroach: 10.0 °F		Temperature S	plit: 20.0 °F	
Low	Normal (1.5 - 12.8)	High	Low	Normal (16.5 - 22.5)	High
	{~}			{~}	

Air Distribution & Filtration

Sample

Total External Static Pressure: 0.50 inH2O		Filter Face Velocity: 480.7 FPM			
Low	Normal (< 0.7)	High	Low	Normal (< 500.0)	High

Subsystem Review

Not yet reviewed

System Diagnostics

No system-wide issues were detected,

Note: The Vitals Score and report can be generated as soon as the system is stable or after 10min.



©2021 Manifold Cloud Services Ltd. | measureQuick.com

	Score Breakdown
Age & Efficiency Losses	
The system age scoring is based upon the initial system SEER, capacity, ins date and climate zone. Larger higher capacity systems in hot climates have shown to age at a faster rate.	stallation -6
Temperature Split Losses	
Split losses are directly tied to sensible capacity. Systems with a low temper split may have a refrigerant charge issue, or more common, a return duct leat that could result in excessive run times and substantial energy losses.	ature O
Static Pressure Losses	
High system static pressure can result in high fan watt draw (electrical usage low airflow as well as premature blower motor failure, especially with ECM/C Torque motors. The system can have high total static, supply static, return si combination of all three. High static can also exacerbate return air duct leak contribute to poor indoor air quality.	e) and/or constant actic or a age and
Approach Losses	
A system with high approach has heat rejection issues. This can be the resula dirty condenser, non condensibles, condenser clearances, and/or condenser recirculation. Systems with a high approach may also have a low temperature split due to heat returning to the metering device through the liquid line.	It of eer air e O
Refrigerant Charge Losses	
Refrigerant charge losses can be the result of a refrigerant undercharge, over and/or non-condensibles. measureQuick considers the deviation in charge from superheat/subcooling targets as well as the metering device type. Fixed piston metering devices will result in high capacity losses when the system is undercharged.	ercharge d/ s
Your System Score	Kepe.
Using data from several studies that correlate system faults, and system deg due to age, measureQuick uses a proprietary scoring system to grade the sy based upon age and system fault intensity. New systems when properly inst should easily score 95-100%.	radation stem alled

Connect. Perform. Prosper.



Test Out Measurement Details

Jane Smith 1423 Main St Your City, OH 54321

Date of Service: 6/12/2022 Time of Service: 11:17:56 AM

What Are Your System Vitals?

Just like your health vitals, temperature, pulse, blood pressure etc, your A/C system vitals show the overall health of your air conditioning system. These vitals account for both the refrigerant and air delivery side of the system. System targets that are out of range are typically related to a system diagnostic listed below. Correcting the diagnostic faults, if possible, should put the system vitals back in the normal range.

YOUR SYSTEM SCORE

93% A-

Outdoor Measurements

Low Pressure (PSIG)	118.0	Job Link
High Pressure (PSIG)	350.0	Job Link
Suction Line Temp (F)	50.0	Job Link
Liquid Line Temp (F)	95.0	Job Link
Discharge Line Temp (F)	170.0	
Outdoor Air Temp (F)	85.0	Job Link
Superheat (F)	10.3	⊞
Subcooling (F)	11.9	⊞
Compression Ratio	2.7	▦
Cond. Volts	230.2	f
Cond. Amps	4.1	f
Cond. Power Factor	0.95	ł
Cond. Power (W)	2012	A

Indoor Measurements

Job Link Job Link 翩 ob Link ob Unk 翩

囲

Job Link

Return Temp (F)	75.0
Return %RH (%)	50.0
Return Wet Bulb (F)	62.6
Supply Temp (F)	55.0
Supply %RH (%)	81.0
Supply Wet Bulb (F)	51.8
Est. Airflow (SCFM)	1149
TESP (inH2O)	0.50
AHU Volts	110.0
AHU Amps	3.0
AHU Power Factor	0.95
AHU Power (W)	980

System Info & Weather

System Type	Split	
Nominal Tonnage (Tons)	3	
Refrigerant	R410A	
Rated Airflow	400	
SEER	13-16	
Metering Device	TXV	
Atmos. Pressure (psia)	14.696	
Elevation (ft)	5012	
Benchmarked	Yes	
System Stability	Stable	

Performance Calculations

Nominal Capacity (Tons/Btuh)	3.0 / 36,000
Normalized Capacity (Tons/Btuh)	2.7 / 32,676
Actual Capacity (Tons/Btuh)	2.9 / 34,827 (107% Normalized)
Sensible Capacity (Tons/Btuh)	2.1 / 25,002 (103% Normalized)
Latent Capacity (Tons/Btuh)	0.8 / 9,825 (117% Normalized)
Sensible Heat Ratio	0.7
Temp Split Target (F)	18.7
Temp Split (F)	20.0
Dehumidification (lb/hr)	9.1
Fan Efficacy (W/SCFM)	0.9
Total Power (W)	2992
EER	11.6
Approx. SEER	12.9



rØ

©2022 Manifold Cloud Services Ltd. | measureQuick.com



System Information

Coords: 40.42773, -105.07575 Condenser Goodman VSX130181 S/N 1909035516 Air Handler Goodman FT130181 S/N 190903870

Corrective Measures

System Profile

System Type	Split
Nominal Tonnage	3
Refrigerant	R410A
Nominal Airflow	400
SEER	13-16
Metering Device	TXV
System Benchmarked	Yes
System Stability	Stable



Corrective Actions

Thermostat Plugged wire penetration

Electrical System Repaired bad wiring/connections Repaired/tightened connections Checked ground connections

Air Distribution System Cleaned blower Cleaned evaporator

Air Filtration System Replaced filter

Condensate Drain System No action required Other

Refrigerant Charge No action required



Indoor Equipment Cleaned evaporator

Cooling Capacity Operation satisfactory

Cooling Efficiency Operation satisfactory Note: these are simple checkboxes that the technician enters during the assessment or repairs

tem

©2022 Manifold Cloud Services Ltd. | measureQuick.com



Report Information

A/C System Vitals Report

measureQuick A/C System Vitals Score[™] combines the cooling performance, age degradation, initial SEER and capacity, refrigerant charge, and static pressure of the duct system into a single grade.

Your system is comprised mechanical equipment and several subsystems including the control, electrical, air distribution, air filtration, and condensate disposal systems. Servicing and or replacing the mechanical equipment without addressing the subsystems only assures premature equipment failure.

Modern A/C systems are designed to last between 10 and 15 years but only when properly installed*. System life is dramatically shortened due to poor installation or long deferred maintenance.

- Systems scoring 80 or more are typically considered excellent candidates for repair.
- Systems scoring under 50 may require significant repairs. These systems may be better candidates for replacement.

Refrigerant Charge (Superheat and Subcooling)

A/C equipment works by using expensive refrigerant to remove heat from inside a room. Superheat and Subcooling are used to determine the precise amount of refrigerant to sufficiently "charge" the equipment. Moreover, these same calculations may further indicate refrigerant leakage and contamination.

Contaminated refrigerant causes unwanted chemical reactions like forming acids, which literally eat your system alive. Likewise, the incorrect refrigerant charge increases energy consumption while reducing equipment life, cooling capacity, and humidity removal.

Heat Transfer (Approach and Temperature Split)

Fundamentally, air conditioners transfer heat from places where it's not wanted (inside your home) to other places (outside your home). This is accomplished by blowing inside air across cold coils (the evaporator). The evaporator is filled with refrigerant. The refrigerant is raised in temperature pumped to the condenser unit (the unit outside) to cool thereby transferring the heat outside.

The efficiency of condenser heat transfer is determined by subtracting the temperature of the refrigerant coming out of the condenser (the cooled refrigerant) from the outdoor temperature; this is called the "approach". A high approach means the refrigerant is not cooling efficiently.

The performance of the evaporator is determined by comparing the temperature of cool air blowing out of your vents and the temperature of the air returning to the system; this is called the temperature split.

Temperature splits that are too high indicate low airflow and can cause the evaporator coil to freeze up. A low temperature split may indicate a refrigerant undercharge, possible leak, or return air duct leakage. Either way, the system will run excessively reducing the equipment life and increasing energy consumption.

Air Distribution and Filtration (TESP and Filter Face Velocity)

Total External Static Pressure (TESP) is a measure of the resistance to airflow in an air conditioning system by components external to the rated appliance.

Typically, the evaporator, air filter, filter grill, registers, supply and return ducts all reduce the airflow. We can measure the resistance by measuring static pressure i.e., pressure in the ducts.

A high TESP means low airflow. Low airflow means longer system run times causing higher energy costs, premature failures, expensive repairs.

Filter face velocity is the speed of the air flowing across the filter. It's measured to assure proper air filter sizing. An undersized air filter permits dirt to flow to the evaporator coil. Evaporator coils, wet from condensation, will attract dirt sticking too and eventually clogging the evaporator coil reducing the cooling efficiency.



©2021 Manifold Cloud Services Ltd. | measureQuick.com



Project Photos



Thermostat



Electrical System



Air Distribution System

measi

nnect. Perform. Pro



Electrical System



Electrical System



Air Distribution System

©2021 Manifold Cloud Services Ltd. | measureQuick.com



Project Photos



Air Distribution System



Air Filtration System





Air Distribution System



Air Filtration System



Condensate Drain System

©2021 Manifold Cloud Services Ltd. | measureQuick.com

Disclaimer: This report was prepared by your service technician who is solely responsible for its content. This report is provided "as-is" excluding all warranties expressed or implied including without limitation the warranty of merchantability.



Condensate Drain System





Project Photos



Outdoor Equipment



Outdoor Equipment

Indoor Equipment



Outdoor Equipment



Indoor Equipment



Cooling Capacity



©2021 Manifold Cloud Services Ltd. | measureQuick.com

Disclaimer: This report was prepared by your service technician who is solely responsible for its content. This report is provided "as-is" excluding all warranties expressed or implied including without limitation the warranty of merchantability.

Je F



Equipment Photos



General





©2021 Manifold Cloud Services Ltd. | measureQuick.com